

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2

Dated: 11-05-2023

It is certified that an inspection team headed by HARISH KUMAR SHRIVASTAVA
(Name of Officers with designation) from G.M.O. NAGAR PALIKA, RAGHOGARH
(Name of Department/ Office) inspected the HINDUPAT PUBLIC SCHOOL, RAGHOGARH
(Name & Address of the school) on 11-05-2023 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
The above is valid for a period of 05 YEARS.

Signature with Seal: 

Name : मुख्य नगरपालिका अधिकारी

Designation : न.पा.सबौगढ़-विजयपुर
जिला-गुना (म.प्र.)

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body


Name & Address of the Office / Department :

To

HINDUPAT PUBLIC SCHOOL,
NEAR KRISHI UPAJ MANDI
BADA BAGH, RAGHOGARH DIST. GUNA M.P
(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

58 | Page


23/05/2023


Secretary
HINDUPAT PUBLIC SCHOOL
Raghogarh, Guna (M.P.)

Principal
Hindupat Public School
Raghogarh, Distt. Guna (M.P.)

WATER TESTING LABORATORY

Public Health Engineering Department Raghogarh (M.P.)

ANALYSIS REPORT

1 SENDER Name & Address A.E. PHE Lab Raghogarh Block & Village: Raghogarh	2. PARTICULARS OF Place of collection & details of sample SAMPLE : (i) विद्युत यंत्रिका घर P.O. Date: 09/05/2023 (ii) _____ Date: _____ (iii) _____ Date: _____ (iv) _____ Date: _____ (v) _____ Date: _____
3 PARTICULARS TO BE FILLED IN THE LABORATORY : Reference No. _____	
4 A. Date & time of receipt 09/05/2023	(B) TESTED ON 10/05/2023
C. Laboratory Reference No. _____	(D) NATURE OF STUDY CHEMICAL/BACTERIOLOGICAL

S.NO	Characteristics	Units	As per BIS -10500 FOR Drinking Water		Results				
			Acceptable	cause for rejection	I	II	III	IV	IV
1	Iron	mg/L	0.1	1.0	0.00				
2	Nitrates	mg/L	45	45	2				
3	Arsenic	mg/L	0.01	0.01	-				
4	Fluoride	mg/L	1.0	1.5	0.5				
5	Chlorides	mg/L	200	1000	10				
6	Total Dissolved Solids	mg/L	500	1500	70				
7	Alkalinity	mg/L	200	600	15				
8	Calcium As "Ca"	mg/L	75	200	16				
9	Magnesium as "Mg"	mg/L	30	100	5.28				
10	Residual Cl ₂	mg/L	0.2	0.5	0.00				
11	Sulphate	mg/L	200	400	-				
12	pH Value	pH Scale	6.5 to 8.5	No relaxation	6.8				
13	Turbidity	NTU	5	10	0.9				
14	Total Hardness	mg/L	200 as CaCO ₃	600 as CaCO ₃	62				
15	E-Coli	MPN/100ml	0.00	0.00	0.00				
16	Coli form	MPN/100ml	0.00	0.00	0.00				
17	Colour	pl Cobalt Scale	5.0	25	-				
18	Temperature	°C	-	-	-				
19	Conductivity	Micromhos/cm	500	2000	130				
20	Test and odour	-	Unobjectionable	Unobjectionable	Unobje				
21	Nitrites (P/A Test)	-	Colour Less (A)	Pink colour (P)	-				

Note :- According to the test Water of given Sample is fit / unfit for drinking Purpose.

Ravi
CHEMIST
 P.H.E. Lab Raghogarh

[Signature]
LAB INCHARGE
 Sub.Division Lab P.H.E.D.
 Raghogan Guna (M.P.)
Secretary
HINDUPAT PUBLIC SCHOOL
 Raghogarh, Guna (M.P.)

[Signature]
सहायक इंजी
 Assistant Engineer
 P.H.E. Sub-Div. Raghogarh
 जिला गुना (म.प्र.)

[Signature]
Principal
 Hindupat Public School
 Raghogarh, Distt.Guna (M.P.)